



Certificate of  
constancy of performance  
**0063-CPR-232190026**  
**Issue: 00**



Issued	24-03-2025	Replaces	
First issued	24-03-2025	Page	1 / 2

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Product description:	External Power Supply, 24VDC 5A, Plastic Case
Trademark:	teknim
Type designation:	TPU-9245P
Hardware / Software:	1.2.3 / 1.1.3
Conditions and essential characteristics:	See Annex 1
Variants:	See Annex 1

placed on the market under the name or trademark of:

Name of the manufacturer:	TEKNİM ELEKTRONİK SAN. ve TİC. A.Ş
Address:	Dudullu OSB Mah. 1. Cad. İsmet Tarman İis Merkezi No:1 K:2 Ümraniye
City:	34776 İstanbul
Country:	Türkiye

and produced in the manufacturing plant(s):

Manufacturing plant:	TEKNİM ELEKTRONİK SAN. ve TİC. A.Ş
Address:	Dudullu OSB Mah. 1. Cad. İsmet Tarman İis Merkezi No:1 K:2 Ümraniye
City:	34776 İstanbul
Country:	Türkiye

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

**EN 54-4:1997**  
**EN 54-4:1997/A1:2002**  
**EN 54-4:1997/A2:2006**  
**EN 54-4:1997/AC:1999**

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**

This certificate was first issued on 24-03-2025 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ron Scheepers  
Managing director

CERTIFICATE

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

Notified Body No. 0063



**Remarks and observations**

The following conditions are applicable:

Essential characteristics of EN 54-4:	Clauses in this European Standard	Performance
Performance of power supply	4, 5, 6	Pass
Operational reliability	4, 5, 6, 7, 8	Pass
Durability of operational reliability; temperature resistance	9.5	Pass
Durability of operational reliability; vibration resistance	9.7, 9.8, 9.15	Pass
Durability of operational reliability; electrical stability	9.9 to 9.13	Pass
Durability of operational reliability; humidity resistance	9.6, 9.14	Pass

**The product as described in this certificate includes the following type designations**

- Product description: External Power Supply, 24VDC 5A, Plastic Case  
- Trademark: teknim  
- Type designation: TPU-9245P  
- Hardware version: 1.2.3  
- Software version: 1.1.3

- Product description: External Power Supply, 24VDC 5A  
- Trademark: teknim  
- Type designation: TPU-9245  
- Hardware version: 1.2.3  
- Software version: 1.1.3