

## BRE Global Ireland

**Notified Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

### 2831-CPR-F4748

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### TFD-4230- Conventional Optical Smoke Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

**Bilgi Elektronik**  
**Dudullu OSB, 1.Cadde İsmet**  
**Tarman İş Merkezi N:1 K:2/32**  
**Ümraniye**  
**34776, Istanbul**  
**Turkey**

**Bilgi Elektronik**  
**Dudullu OSB, 1.Cadde İsmet**  
**Tarman İş Merkezi N:1 K:2/32**  
**Ümraniye**  
**34776, Istanbul**  
**Turkey**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

#### EN 54-7:2018 - Smoke detectors - Point smoke detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 22 June 2022 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 22 June 2022

Date of Issue: 22 June 2022

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

**BRE Global Ireland****Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

T: +353 (0) 18824344

E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F4748****TFD-4230- Conventional Optical Smoke Detector**

## Note:

1. Meets the requirements of EN 54-7 at sensitivity level 1 (default) setting only

## Bases

Standard Base



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 22 June 2022

Date of issue: 22 June 2022

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)